



PUBLIC WORKS AGENCY

P.O. Box 1070 / 777 N. Colusa Street
Willows, CA 95988

Airports
Engineering
Flood Control
Roads & Bridges
Solid Waste
Surveyor

Cole Grube, P.E., Director

TO: All Planholders

FROM: Cole Grube, Director

DATE: May 22, 2020

SUBJECT: Notice to Contractors – Pavement Digout Services - ADDENDUM NO. 1

The following questions have been received in response to the subject Notice to Contractors. The County's response is included, in red, after each question received.

1. What is the minimum width and distance of the digouts?
4' x 6'.
2. Are the digouts laid out right now?
The digouts will be marked by close of business Tuesday, May 26, 2020.
3. Can the County provide a map showing delineation of the area to be prepared?
No. Please see the response to questions 2 above.
4. Will the County or contractor provide the geotech for compaction?
The County will perform quality assurance, which may include compaction testing in addition to observation.
5. Is there any striping on the job?
No.
6. Is there any work to be done within the RxR right-of-way?
No.

Please acknowledge receipt of this addendum on your bid.