



COUNTY OF GLENN

Department of General Services- Facilities
453 E. County Road 49 1/2
Willows, CA 95988
Phone: 530-934-6545
Facilities2@countyofglenn.net
www.countyofglenn.net

SCOTT H. DEMOSS
County Administrative Officer
525 W. Sycamore St. Suite B1
Willows, CA 95988
Phone: 530-934-6400
Fax: 530-934-6419
gcboard@countyofglenn.net

Addendum #3

Solicitation Description: Public and Behavioral Health Exterior Siding Replacement
Solicitation Opening Date, Time: Tuesday, March 21, 2023 at 10:00 a.m.

Location: General Services
453 E. County Road 49 1/2
Willows, CA 95988

Addendum Number: 003
Addendum Date: Friday, March 10, 2023
Contract: Joe Bettencourt, Supervising Staff Services Analyst- General Services
Ricardo Valdez, Facilities Operation Manager- General Services
Facilities2@countyofglenn.net, (530) 934-6545

-
1. Return one properly executed copy of this addendum with bid response or prior to the Bid Opening Date/Time listed above.
 2. Attachment 3. Negative Asbestos Test, is added to 401 Division Specs Attachments.

This addendum has been emailed to interested vendors as well as posted here:
<http://www.countyofglenn.net/govt/bids>

Failure to acknowledge receipt of this addendum may result in rejection of the response.



AdamLabs, Inc.

3807 Pasadena Avenue, Suite 190
Sacramento, CA 95821
Phone: (916) 692-8355

Asbestos Report

claim #: n/a

Date: *March 10, 2023*

Client: *Glen Country*

Site: *240 N Villa Ave
Willows, CA*

On March 10, 2023, an Asbestos Survey was conducted at the above location. Site inspection, sample collection, laboratory analyses, and written report are attached. The inspection area is an occupied commercial building currently planned for restoration. Therefore, building materials will be impacted during the planned restoration in specific to isolated areas of the structure. An assessment of the mentioned materials throughout the areas of impact was made and samples were collected according to the contractor's scope of work. This asbestos survey was conducted to confirm whether, or not asbestos is identified in all suspect building material. Please see attached data sheet LAB #23AB559

Results indicate No Asbestos was detected. The information provided in this report can be used to obtain accurate bids from abatement contractors. Based on sample results, no asbestos was detected in the suspected building materials tested. All other materials that are not part of this survey shall be treated as asbestos containing material until proven otherwise by PLM analyses.

The above site address falls under the jurisdiction and is subject to the requirements of the local Air Quality Management District. The building materials sample collection was conducted by a State OSHA Certified "Site Surveillance Technician" and/or "Asbestos Consultant" under Adam Laboratories Inc. (in accordance with Rule 902 Section 401.3). The location of asbestos containing material, quantity, percent, friability, type of asbestos, and date sampled can be found on the attached analytical lab report.

Approved by,

Adam Jahnsen, Certified Asbestos Consultant, DOSH #00-2813

Any building materials not mentioned in this report should be assumed as ACM until proven otherwise through proper sampling and analysis. This includes other areas that are not mentioned with similar materials. Upon discovery of unmentioned material, work must cease until further sampling is conducted.

This document is filed under lab identification number 23AB559



AdamLabs, Inc.

3807 Pasadena Ave. Ste., 190
Sacramento, CA 95821
Phone: (916) 692-8355
info@adamlabs.com

AIHA Laboratory #163722

Lab #: 23AB559
Date Sampled: 3/9/2023
Date Analyzed: 3/10/2023
Sampled By: Adam Jahnsen
Analyst: Adam Jahnsen

Assessment and Analysis of Bulk Asbestos by Polarized Light Microscopy (PLM) EPA 600/M4 Method

CLIENT:

SITE: 240 N Villa Ave
Willows, CA

CLAIM# n/a

No.	LAYERS	AREA FT ²	LOCATION	DESCRIPTION	I.D.	RACM	RESULT
1	1	*	Ext W wall S end behind wood shingle	tar paper	Cellulose Fibers		NAD
2	1	*	Ext W wall center behind wood shingle	tar paper	Cellulose Fibers		NAD
3	1	*	Ext W wall N end behind wood shingle	tar paper	Cellulose Fibers		NAD

LEGEND

NAD = Non Asbestos Detected. DL = detection limit: <1% asbestos (trace). I.D. = fiber identification and/or asbestos type - percent.

Friable Asbestos = NESHAP RACM (Regulated Asbestos Containing Material): can be crumbled, pulverized or reduced to powder by hand pressure.

Non-friable Asbestos = NESHAP Category I material (resilient floor covering, vinyl floor tile, asphalt roofing products, packings and gaskets that cannot be rendered airborne by hand pressure) and/or NESHAP Category II material (all other non-friable asbestos containing material). Note that because of age or treatment, Category I and Category II materials, can be, and/or have the potential to become RACM.

RACM = NESHAP Regulated Asbestos Containing Material is all Friable ACM (>1% asbestos), including some conditions of Non-friable Category I & II ACM.

NESHAP = US EPA National Emissions Standards for Hazardous Air Pollutants

APPROVED BY:

Adam Jahnsen, Lab Director
Certified Asbestos Consultant
CAL/OSHA: 00-2813

Analytical results represent the analysis of samples collected by AdamLab INC. This report is generated at the request and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies will not be released to a third party without written request from the client. Sample(s) will be retained for a period of twelve months for possible future analytical verification, after which, the sample(s) will be disposed of according to all state and federal guidelines. AdamLabs Inc. is a participant in the BAPAT (Bulk Asbestos Proficiency Analytical Testing) quality assurance program by AIHA (American Industrial Hygiene Association).